FI-66335

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Lithium-ion Rechargeable Battery System

NINGBO DEYE ESS TECHNOLOGY CO., LTD No. 568, South Rixian Road, Binhai Economic Development Zone, Cixi, Ningbo, Zhejiang, China

NINGBO DEYE ESS TECHNOLOGY CO., LTD No. 568, South Rixian Road, Binhai Economic Development Zone, Cixi, Ningbo, Zhejiang, China

NINGBO DEYE ESS TECHNOLOGY CO., LTD No. 568, South Rixian Road, Binhai Economic Development Zone, Cixi, Ningbo, Zhejiang, China

☐ Additional Information on page 2

See page 2

Deye

BOS-BX (X=70, 85, 100, 110, 125, 140, 155, 170, 185, 200, 215)

☐ Additional Information on page 2

IEC 63056:2020 National Differences:

SZES241100790901

This CB Test Certificate is issued by the National Certification Body

SGS Fimko Ltd Takomotie 8 FI-00380 Helsinki, Finland

Signature:

Mark Lohmann Certification Manager

SGS

Date: 2025-10-24



Ref. Certif. No.

FI-66335

Ratings and principal characteristics:

Rated voltage and energy:

BOS-B70: 256,0 Vd.c., 71,5 kWh BOS-B85: 307,2 Vd.c., 85,8 kWh BOS-B100: 358,4 Vd.c., 100,1 kWh BOS-B110: 409,6 Vd.c., 114,4 kWh BOS-B125: 460,8 Vd.c., 128,7 kWh BOS-B140: 512,0 Vd.c., 143,0 kWh BOS-B155: 563,2 Vd.c., 157,3 kWh BOS-B170: 614,4 Vd.c., 171,6 kWh BOS-B185: 665,6 Vd.c., 185,9 kWh BOS-B200: 716,8 Vd.c., 200,2 kWh

BOS-B215: 768,0 Vd.c., 214,5 kWh

Rated capacity: 280 Ah

SGS Fimko Ltd Takomotie 8 FI-00380 Helsinki, Finland

Signature:

Mark Lohmann Certification Manager

Issued 2018-06-05

Date: 2025-10-24

2/2